

## **ADDENDUM NO. 5**

**RENOVATIONS AND ADDITION TO BERRYVILLE PRIMARY  
CLARKE COUNTY PUBLIC SCHOOLS  
BERRYVILLE, VIRGINIA**

**IFB #16-1117**

**COMM. NO. 12171-02**

**RRMM ARCHITECTS  
ROANOKE, VIRGINIA**

**November 14, 2016**

The following additions, deletions, and/or modifications are to be incorporated into the Contract Documents and acknowledgement of receipt of this addendum shall be so noted on the Proposal Form submitted.

### **SPECIFICATIONS:**

Not used this addendum.

### **DRAWINGS:**

Not used this addendum.

### **QUESTIONS FROM BIDDERS:**

- Q: Plan AD-101 note #10 states to provide new lintels at demoed opening at new elevator. S-102 and Section 5/S-302 show opening as existing and does not show lintels.
- A: The opening in the existing basement level wall is incorrectly indicated as existing in section 5/S-302. Install lintels for this new opening in the existing wall per the lintel schedule on sheet S-102.

### **CLARIFICATIONS:**

Not used this Addendum.

### **ATTACHMENTS:**

Not used this addendum.

**END OF ADDENDUM NO. 5**